



Procurement Office
495 Upper Falls Blvd.
Rochester, NY 14605
Fax: 585-697-7164
WWW.ROCHESTERHOUSING.ORG

May 3, 2021

ADDENDUM #1

To: Potential Bidders

RE: Rochester Housing Authority

Replace Steam Boiler and Feedwater Set
Kennedy Tower
1 Pages including this cover sheet

Q: Your scope of work for the Kennedy Tower steam boiler project says the contractor is to supply a feedwater tank "vertical style of stainless-steel construction". Further down it lists the specification as having a carbon steel tank. Please clarify if you are specifying a stainless steel or carbon steel feedwater tank.

A: Thank you, that was an error. The contractor will supply a **vertical style tank of stainless-steel construction**. There is an illustration of the preferred tank on page 26 of the bid scope.

Acknowledgement:

I have received the above referenced Addendum #1 and have used it in the calculation/preparation of this bid.

Contractor

Without acknowledgement of this addendum your bid may be non-responsive.